

**Johanna Scutt**

---

**From:** Toby@stinson-beach-cwd.dst.ca.us  
**Sent:** Monday, November 19, 2018 8:57 AM  
**To:** johannas@bolinas-stinson.org  
**Subject:** Lead sampling results  
**Attachments:** SBCWD 11-6 Pb-School.pdf

Johanna.

Please see the attached lead sampling results for the Stinson Beach campus. Two samples were drawn, one from the faculty room kitchen sink and the other from the drinking fountain near the lunch area, both samples came back as none detected.

Thank you.

Toby Bisson,  
SBCWD Water Supervisor

GENERAL MINERAL & PHYSICAL & INORGANIC ANALYSIS (9/99)

Date of Report: 18/11/15

Sample ID No.1118-22839

Laboratory

Signature Lab

Name: BRELJE & RACE LABORATORIES, INC

Director: *Jim Bond*

Name of Sampler:KV

Employed By: BOLINAS-STINSON ELEM

Date/Time Sample

Date/Time Sample

Date Analyses

Collected:18/11/06/0510

Received @ Lab:18/11/06/0000

Completed:18/11/07

System

Name:STINSON BEACH COUNTY WTR DIST

System

Number: 2110004

Name or Number of Sample Source:Bolinas Stinson Elem-Faculty Room Kitch

\*\*\*\*\*

\* User ID: RXR

Station Number: 2110004-AAB-B \*

\* Date/Time of Sample: |18|11|06|0510|

Laboratory Code: 9534 \*

\* YY MM DD TTTT

YY MM DD \*

\* Date Analysis completed: |18|11|07| \*

\* Submitted by: \_\_\_\_\_

Phone #: \_\_\_\_\_ \*

\*\*\*\*\*

PAGE 1 OF 1

INORGANIC CHEMICALS

| MCL  | REPORTING | CHEMICAL         | ENTRY | ANALYSES | DLR |
|------|-----------|------------------|-------|----------|-----|
|      | UNITS     |                  | #     | RESULTS  |     |
| ug/L |           | Lead (Pb) (ug/L) | 01051 | < 5.0    | 5.0 |

+ Indicates Secondary Drinking Water Standards